443 Lafayette Road N. St. Paul, Minnesota 55155 www.doli.state.mn.us



Construction Codes & Licensing Division

June 26, 2008

Mr. Daniel Stevens CDC Enterprises, Inc. 13355 George Weber Drive, Suite M Rogers, MN 55374

Subject:

State Appeals Board results of June 17, 2008 - #08-01

Dear Mr. Stevens.

This is to confirm that the State Appeals Board has approved your appeal of the decision by the Dayton Building Official in the matter of the insulating properties of the AKDUCT installed at the King Companies building under construction at 11011 Holly Lane in Dayton, Minnesota. The vote was 5-0 in favor of your appeal with any conditions as listed in the minutes of the meeting (see enclosed). The Board finds that AKDUCT's thermal properties satisfy the intent of the Minnesota Building Code (Minnesota Rule 1346.0603 Subpart 7; 603.7.6).

By way of this letter we are notifying the building official that the AKDUCT and its equivalent R-value is approved for installation at this location. Construction/installation shall be in accordance with the design submitted with your application for appeal and any condition(s) listed in the minutes. The building official is responsible to see that the completed installation complies accordingly including any other applicable provisions of the Minnesota Building Code.

CONSTRUCTION CODES & LICENSING DIVISION Sincerely,

Thomas Downs Jr., Chair

Thomas Lowns

State Appeals Board

Enc:

Minutes \

Cc:

Loren Kohnen, Dayton Building Official

Appeals Board Members

Tom Anderson, State Building Official

All registered attenders